



May 11, 2016

**ADDENDUM NO. 3 TO ALL BIDDERS:**

Invitation to Bid: ITB# 16-08-16

Description: Williamson Road Library

Dated: April 15, 2016

For Delivery to: Purchasing Division, City of Roanoke, Virginia

Bids Due: May 17, 2016

**BIDS FOR ITB#16-08-16, WILLIAMSON ROAD LIBRARY ARE DUE ON MAY 17, 2016, BY 2:00P.M.**

**1. REFERENCE: SPECIFICATIONS, SECTION 272000, PATHWAYS FOR DATA NETWORK SYSTEM.**

The data rack, rack components, patch panel, UPS, copper data cable, data jacks, patch panel jacks, copper jumpers, icons and outside fiber optic cabling outlined in spec section 272000 and Owner provided data switches are Not In Contract and will be installed and tested by the Owner. The base bid shall include the installation of junction boxes, conduits, raceways, pull strings, identification and grounding.

**2. REFERENCE: SPECIFICATIONS, SECTION 282000, ELECTRONIC SURVEILLANCE (CONDUIT & CABLING).**

The CCTV wiring and equipment specified in section 282000 is Not in Contract and will be installed and tested by the Owner. The base bid shall include the installation of junction boxes, conduits, raceways, pull strings and grounding.

**3. REFERENCE: REQUEST FOR SUBSTITUTION OF PRODUCTS, TECHNICAL SPECIFICATIONS, VARIOUS, ADD:**

Specification Section 084229 Sliding Door Entrances. Stanley Automatic Doors are an approved substitution product.

4. **REFERENCE: TECHNICAL SPECIFICATIONS, SECTION 072100, THERMAL INSULATION, CERTIFICATION, MODIFY:**

The installer will not be required to be accredited by the Air Barrier Association of America (ABAA). The installer must have a quality assurance program in place similar to the ABAA Quality Assurance Program. The installer must show experience with similar materials and have a proven record of successful in-service performance. All referenced standards will be enforced.

**Note:** A signed acknowledgment of this addendum should be received at the location indicated on the RFP either prior to the due date and hour or attached to your response. Signature on this addendum does not substitute for your signature on the original solicitation document. The original solicitation document must be signed.

Very truly yours,

Monica Cole  
Senior Buyer

Phone: 540-853-2871

\_\_\_\_\_  
Name of Firm

\_\_\_\_\_  
Signature/Title

\_\_\_\_\_  
Date